# LINCOLN COUNTY
# DEPARTMENT OF ENVIRONMENTAL HEALTH
# WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 06/01/2022 Expiration Date: 05/30/2023

Property Owner: Jayanta Barua & Hemanta Nath c/o:

Address: [redacted]

Telephone: (Home) [redacted] (Work)

Installer: License No.

Proposed Work: (Check One) ☒ New Installation ☐ Existing System

☐ Repair ☐ Replacement ☐ Extension ☐ Other _____

Describe: Four 95 foot laterals, gravity flow, standard trenches

*Parcel Description:*

Legal: S18 T36N R27W, COS 1038 Remainder

Address or Location: 4070 Black Lake Rd, Rexford, MT

*Approved Design Criteria:*

# Bedrooms: 3 Septic Tank Size: 1000 gallon Drainfield Size: 375 lineal feet

**SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!**

***Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.***

**Issued By:** Kathi J. Hooper, R.S.

Closure Statement:

*I, Bradley S. Persson have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

*Signed:* [signature] *Date:* Sep 16 2022

*Title:* Installer #159

**NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.**

**406-293-2442**

***DISCLAIMER***


This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

$

NOTE:
THE PARCELS IS UNDEVELOPED
ALL SHOWN AS PROPOSED DEVELOPMENT
(LIVING UNIT, DRIVE, SEPTIC SYSTEM, WELL)

# BARUA PROPERTY
# REMAINDER COS 1038
# WATER AND SEWER
# LOT LAYOUT

SECTION 18-T36N-R28W
LINCOLN COUNTY





Jon Johnson, RS
4572 Whitefish Stage Road
Whitefish MT 59937