LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 10/18/2023 Expiration Date: 10/17/2024

Property Owner: Ray & Wendy Bicknell

Mailing Address: [redacted]

Telephone: [redacted] E-mail: [redacted]

Installer: Kootenai Sand & Gravel License #: 109

Approved Work: (Check One) ☒ New Installation ☐ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: New Pressure Dosed system with 3 Laterals @ 42'.

Parcel Description:

Legal: MORAINE, S12, T37 N, R27 W, LOT 4, ACRES 0.898, PM 6994

Property Address: 78 Moraine Dr. N. Eureka, MT 59917 Assessment Code: 16890

DEQ COSA: EQ#08-2392 Date: 11/19/2008

Approved Design Criteria: New Pressure Dosed system with 3 Laterals @ 42'.

# of Bedrooms: 3 Septic Tank Size: 1000/500 gallons Trench Width: 36"

# of Laterals: 3 Length of Laterals: 42' Trench Depth: 24"-36"

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the COSA, lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. It is the installer's responsibility to ensure that all required horizontal setbacks are met. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: Robin Blumberg, SIT

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:

This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.

Signed: Robin Blumberg *Date:* 12/1/23

____ Lincoln County Health Department (LCHD) ____ Licensed Installer w/ approval of LCHD

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

SV

APPROVED
Montana Department of
Environmental Quality ASSESSMENT CODE: 16890

MORAINE SUB. LOT 4 LAYOUT
R. BICKNELL — DETAILED AREA PROPOSED SEPTIC

Reviewer 11/22/2023 Date

