

**LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT**

Permit # 12955

Issue Date: 09/27/2023

Expiration Date: 09/26/2024

Property Owner: Glen Cameron

Mailing Address: [REDACTED]

Telephone: [REDACTED]

E-mail: [REDACTED]

Installer: Marty Goucher

License #: 196

Approved Work: (Check One)

☒ New Installation

☐ Existing System

☐ Replace Drainfield

☐ Replace Tank

☐ Extension

Describe: Installation of new pressure dosed septic system.

Parcel Description:

Legal: VALLEY RIDGE, S33, T37 N, R27 W, LOT 1, ACRES 9.55, PM 5696

Property Address: 600 Valley View Loop Eureka, MT 59917 Assessment Code: 12955

DEQ COSA: EQ#27-85-S23-429

Date: 07/28/93

Approved Design Criteria: Installation of new pressure dosed system w/3 lateral@68'.

of Bedrooms: 3

Septic Tank Size: 1000/500

Trench Width: 36"

of Laterals: 3

Length of Laterals: 68'

Trench Depth: 24"-36"

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the COSA, lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. It is the installer's responsibility to ensure that all required horizontal setbacks are met. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: *Robin Blumberg, R.S.*

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:

This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.

Signed: _____

Robin Blumberg

Date: _____

6/12/24

☒ Lincoln County Health Department (LCHD)

Licensed Installer w/ approval of LCHD

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

SV

