LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 04/14/2025 Expiration Date: 04/13/2026 Permit#25-10796

Property Owner: Christian Life Center of Las Vegas/ John Theonnes

Mailing Address: [redacted]

Installer: Marty Goucher License #: 196

Approved Work: (Check One) ☒ New Installation ☒ Existing System

☒ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Installation of new pressure dosed system to replace failed system for Church with 450 GPD usage.

Legal: S04, T30 N, R31 W, ACRES 2.072, TR G2AA IN NENWSE

Property Address: 155 Mahoney Rd., Libby, MT 59923 Assessment Code: 10796

DEQ COSA: E.Q.# Date:

Approved Design Criteria: Installation of new pressure dosed system to replace failed system for Church with 450 GPD usage with 2 Laterals @ 70' with reduction for chambers.

# of Bedrooms: 450 GPD Septic Tank Size: 1500/500 Trench Width: 36"

# of Laterals: 2 Length of Laterals: 70' Trench Depth: 24"-36"

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, Circular DEQ-4, and COSA(If Applies). Reduction given for chambers. It is the installer's responsibility to ensure that all required horizontal setbacks are met. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: *Robin Blumberg, RS*

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:


This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

This permit is not finalized until the system is inspected and the closure statement is signed.

This permit is not a guarantee that the system will function properly for a prescribed period of time.

SJ


50 feet from property line
12 feet
177 feet from property line
Well
120 Ft
500 Gal dosing tank
Christian life center Church 155
Mahoney Rd Libby MT
297 feet
to Mahoney
Rd
165 feet from existing tank
to drainfield
Existing 1500 Gal
Tank
Mahoney Rd