# LINCOLN COUNTY HEALTH DEPARTMENT
## ENVIRONMENTAL HEALTH
## WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Permit #24-12604

Issue Date: 06/04/2024 Expiration Date: 06/03/2025

Property Owner: Daniel Cosgrove

Mailing Address: [redacted]

Installer: Buck Schermerhorn License #: 135

*Approved Work:* (Check One) ☒ New Installation ☐ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Installation of new elevated sand mound for 3 Bedroom House.

*Parcel Description:*

Legal: EAGLE CREST, S33, T36 N, R28 W, LOT 1, ACRES 20.1, PM 6931

Property Address: 2384 Phills Lake Road, Rexford, MT 59930. Assessment Code: 12604

DEQ COSA: EQ# Date:

*Approved Design Criteria:* Installation of new elevated sand mound for 3 Bedroom House.

# of Bedrooms: 3 Septic Tank Size: 1500/500 gallons Trench Width:

# of Laterals: See Design Drawing Length of Laterals: Trench Depth:

**SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!**

*Special Instructions: Install system according to the COSA, lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. It is the installer's responsibility to ensure that all required horizontal setbacks are met. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.*

**Issued By:** *Robin Blumberg, R.S.*

**NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.**

Closure Statement:


*This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.*

*Signed:* Robin Blumberg *Date:* 8/9/24

____ Lincoln County Health Department (LCHD) ____ Licensed Installer w/ approval of LCHD


***This permit is not finalized until the system is inspected and the closure statement is signed.***

***This permit is not a guarantee that the system will function properly for a prescribed period of time.***




DANIEL COSGROVE SITE LAYOUT

**LOT 1**
20.1 ACRES
2384 PHILLS LAKE RD, REXFORD, MT 59930
S33, T36N, R28W, EAGLE CREST
ASSESSMENT #0000012604
GEO 56-4822-33-2-04-01-0000




SEPTIC SYSTEM LAYOUT

MONTANA DESIGN SERVICES
COSGROVE SEPTIC
SITE LAYOUT
3/19/24
5/7/24
1