NEW

LINCOLN COUNTY
SEPTIC SYSTEM PERMIT NO. _____

ISSUED TO: Faith Christian Center DATE: 4-19-82

ADDRESS: _____ Troy, PHONE: [redacted]

ISSUED BY (sign.) Johnnie Peterson, R.S.

INSPECTION BY (sign.) _____ DATE: _____

(You must notify the Department of Environmental Health a minimum of 8 working day hours before backfilling the septic system, so that it can be inspected.)

CONTRACTOR: Self

DESCRIPTION OF SYSTEM:

LOCATION OF PROPOSED SYSTEM Next to Wilderness Plateau Jct 56 & US2

SEPTIC TANK 1000 gal. ABSORPTION AREA: 400 ft²

SEWAGE DISCHARGE — gal/day No. OF BEDROOMS —

WATER SUPPLY SOURCE Shared Well SOIL Rocky Loams SLOPE 1-3%

DRAINFIELD INSTRUCTIONS: Dig a ditch 200' long x 2½-3' deep x 2' wide according to lot layout and septic system regs. Slope of pipe should not exceed a 1% drop.

SKETCH OF LOT LAYOUT:

