LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 09/09/2021 06/20/23(Renewal) Expiration Date: 06/20/2023

Property Owner: David Lilly c/o:

Address: [redacted]

Telephone: [redacted] (Home) (Work)

Installer: Logan Munts License No.: 160

PIQ.posgd-W.Q.tk: (Check One) —XXX— New Installation Existing System

____ Repair Replacement Extension Other

Describe: 3 66' laterals w/ infiltrators

Parcel Description:

Legal: S21 T34N R34W

Address or Location: 4037 Pine Creek Rd., Troy, MT 59935

Approved Design Criteria:

Bedrooms: 3 Septic Tank Size: 1000 gallons Drainfield Size: 198 Linear Feet

System must include installation effluent filter at septic tank outlet

Special instructions: INSTALL SYSTEM ACCORDING TO LAYOUT AND LINCOLN COUNTY WASTEWATER REGULATION. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT. Issued By: Dustin Webb, RS

Closure Statement:

_____, have inspected this system and found it to be in compliance with the conditions of the permit, and the lincoln County Wastewater Treatment and Disposal Regulation #3 Signed:_____ Date:

NOTICE: The Department must be notified at least 4hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

LOT LAYOUT

4037 Pine Creek Rd
Troy, MT 59935

