Permit # 23-14363

LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 09/08/2023 Expiration Date: 09/07/2024

Property Owner: Eric McClendon

Mailing Address: [redacted]

Telephone: [redacted] E-mail: [redacted]

Installer: Mountain Contracting License #: 3

Approved Work: (Check One) ☒ New Installation ☐ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Installation of new gravity system with 4 Laterals@84'.

Parcel Description:

Legal: S25, T36 N, R26 W, COS 4801, PARCEL TRACT 1, ACRES 20.248

Property Address: 486 Haven Bend Eureka, MT 59917 Assessment Code: 14363

DEQ COSA: EQ# Date:

Approved Design Criteria: Installation of new gravity system with 4 laterals @84' for existing one bedroom cabin and future 2 bedroom dwelling.

# of Bedrooms: 3	Septic Tank Size: 1500	Trench Width: 24"
# of Laterals: 4	Length of Laterals: 84'	Trench Depth: 24"-36"

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the COSA, lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. Reduction given for chambers. It is the installer's responsibility to ensure that all required horizontal setbacks are met. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: Robin Blumberg, SIT

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:

This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.

Signed: Robin Blumberg *Date:* 9/22/23

✓ Lincoln County Health Department (LCHD) ____ Licensed Installer w/ approval of LCHD

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

Assessment Code _____ 5

LOT LAYOUT

