LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 10/21/2022 Expiration Date: 10/20/2023

Property Owner: Dale McLaury

Mailing Address: [redacted]

Telephone: [redacted] Email: [redacted]

Installer: Tony Berget License #: 26

Approved Work: (Check One) ☒ New Installation ☐ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Gravity system with standard trenches using chambers

Parcel Description:

Legal: Double Creek Lot 4, S17 T30N R33W, 10.51 acres

Property Address: 178 Double Creek Ln Assessment Code: 52560

Approved Design Criteria:

# of Bedrooms: 3 Septic Tank Size: 1000 gallons Trench Width: 24 inches

# of Laterals: ~~X~~5 (RB) Length of Laterals: ~~84~~ feet 68 (RB) Trench Depth: 24-36 inches

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. 10% reduction given for chambers. ANY CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kathi J. Hooper, R.S.*

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:

I, Robin Blumberg, *have inspected this system and found it to be in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.*


Signed: Robin Blumberg *Date:* 7/11/23

✓ Lincoln County Health Department (LCHD) ____ Licensed Installer w/ approval of LCHD

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

$


ANA
ION
N 17,
M.
DATE: DECEMBER 2005
EQ No
06-297
31/07
CREEK
GRADIENT DIRECTION
CREEK
LOT 4
10.56 ACRES±
(NET: 10.51 ACRES±)
SET
OT 3
ACRES±
24 ACRES±)
LOT 5
9.49 ACRES±
(NET: 9.45 ACRES±)
PLAIN
SLOPE 1%
SET
LOT 6
9.04 ACRES±
(NET: 8.96 ACRES±)
BACK
SLOPE 1%
18" CMP
SLOPE 1%
BACK
LINE
LOT 7
9.06 ACRES±
(NET: 8.90 ACRES±)
LAKE
18" CMP
OAD
RECEIVED