LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 11/12/2022 Expiration Date: 11/11/2023

Property Owner: Louis Mosto

Mailing Address: [redacted]

Telephone: [redacted] Email: NA

Installer: Charley Follensbee License #: 96

Proposed Work: (Check One) ☒ New Installation ☐ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Pressure dosed system with 3' wide chambers

Parcel Description:

Legal: Eureka Hills Subdivision, Lot 23, S26 T36N R27W, 2.767 acres

Property Address: 762 Hillandale Trail, Eureka Assessment Code: 54978

Approved Design Criteria:

# of Bedrooms: 2 Septic Tank Size: 1500/500 gallons Trench Width: 36 inches

# of Laterals: 3 Length of Laterals: 84 feet Trench Depth: 24 – 36 inches

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. ANY CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kathi J. Hooper, R.S.*

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-293-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:

I, Charles Follensbee, *have inspected this system and found it to be in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.*

Signed: _____ *Date:* 4/9/23

____ Lincoln County Health Department (LCHD) X Licensed Installer w/ approval of LCHD

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

5/

LOT LAYOUT

