Permit # 24-52587

LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 02/14/2024 Expiration Date: 02/13/2025

Property Owner: Charles Noble

Mailing Address: [redacted]

Installer: Logan Munts License #: 160

Approved Work: (Check One) ☒ New Installation ☐ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Installation of new gravity system with chambers.

Parcel Description:

Legal: CABINET VISTA ESTATES PH 2, S06, T29 N, R33 W, LOT 8, ACRES 5.01, PM 6872

Property Address: 187 Lower Stanley Cutoff Rd. Troy, MT 59935 Assessment Code: 52587

DEQ COSA: E.Q.# 07-1742 Date: 01/23/2007

Approved Design Criteria: Installation of new gravity system with 2 laterals @ 64' with reduction given for chambers.

# of Bedrooms: 1 Septic Tank Size: 1000 gallons Trench Width: 24"

# of Laterals: 2 Length of Laterals: 64' Trench Depth: 24"-36"

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the COSA, lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. Reduction given for chambers. It is the installer's responsibility to ensure that all required horizontal setbacks are met. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: *Robin Blumberg, RS*

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:

This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.

Signed: Robin Blumberg *Date:* 2/27/24

✓ Lincoln County Health Department (LCHD) ____ Licensed Installer w/ approval of LCHD

This permit is not finalized until the system is inspected and the closure statement is signed.

This permit is not a guarantee that the system will function properly for a prescribed period of time.

LINCOLN COUNTY, MONTANA
CABINET VISTA ESTATES PHASE II
IN THE W1/2 SE1/4 OF SECTION 6 AND THE W1/2 NE1/4 OF SECTION 7, TWP. 29 N., R. 33 W., P.M.M.
REVISED LOT LAYOUT - LOT 8

APPROVED
Montana Department of
Environmental Quality
Reviewer 2/09/2024
Date
EQ#07-1742

GRADIENT DIRECTION

LEGEND

- SOILS PROFILE
- PERCOLATION SITE
- PROPOSED WELL SITE
- STORMWATER POND 30'X 20'X 2'
- SLOPE
- GRADIENT DIRECTION
- PROPOSED SEPTIC SITE 3-85' TRENCHES 10' APART
- 200' MIXING ZONE



SCALE: 1" = 145'

