LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Permit # 23-12382

Issue Date: 07/27/2023 Expiration Date: 07/26/2024

Property Owner: Angelo Zeno Perucci

Mailing [redacted]

Telephone: [redacted] E-mail: [redacted]

Installer: Paul Dalziel License #: 175

Approved Work: (Check One) ☒ New Installation ☐ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Installation of new septic system with reduction given for chambers.

Parcel Description:

Legal: YAAK MEADOWS 1ST ADDN HES 403, S31, T36 N, R31 W, BLOCK 1, ACRES 1.79, LOT33 *12382*

Property Address: 517 River View Dr. Troy, MT 59935 Assessment Code: 12382

DEQ COSA: ES#27-72-679 72/33 Date: 06/02/72

Approved Design Criteria: Installation of new septic system with chambers.

# of Bedrooms: 2 Septic Tank Size: 1000 gallon Trench Width: 24"

# of Laterals: 2 Length of Laterals: 52' Trench Depth: 24"-36"

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the COSA, lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. Reduction given for chambers. It is the installer's responsibility to ensure that all required horizontal setbacks are met. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: Robin Blumberg, SIT

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:

This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.

Signed: Robin Blumberg *Date:* 8/21/23

____ Lincoln County Health Department (LCHD) ____ Licensed Installer w/ approval of LCHD

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

SI

Assessment Code 00000 12382

LOT LAYOUT

