PERMIT

Issue Date: 11-16-93 Permit No. _____

Property Owner: GERALD & SANDRA SCHUHMACHER Io: _____

Address: [redacted]

Telephone: (Home) [redacted] (Work) [redacted]

Installer: Koocanusa Plumbing License No. 8

✓ New Installation _____ Existing System

_____ Repair _____ Replacement _____ Extension _____ Other

Describe: _____

Parcel Description:

Legal: BERGER LAKE SUBDIV. LOT 3 NW¼S25T37R27

Address or Location: _____

Approved Design Criteria:

Septic Tank Size: 1000 gallons Drainfield Size: 195 lineal feet

Special Instructions: Sandlined drainfield required.

Approved Site plan (Lot Layout) Attached


Issued By: John W Peterson, RS

Closure Statement:

I, Michael B Nelson *, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Michael B Nelson *Date:* 30 Dec 1994

Title: _____


N
Drainfield Replacement Area
well
100' Minimum
65'
DRAIN
10'
FIELD
10'
Distrib box
10'
Septic Tank
10'
House
DRIVEWAY
* Note -
Proposed well site must be at least 100' from approved drainfield site for lot 4