LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 03/31/2023 Expiration Date: 03/31/2024

Property Owner: Derrick & Suzanne Smith

Mailing Address: [redacted]

Telephone: [redacted] E-mail: [redacted]

Installer: Self- Homeowner License #: N/A

Approved Work: (Check One) ☒ New Installation ☐ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Pressure dosed system w/standard 3' wide trenches, chamber

Parcel Description:

Legal: SW1/4 of S15 T37N R28W PPM

Property Address: 183 Enchanted Way, Rexford, MT 59930 Assessment Code: 55670

Approved Design Criteria:

# of Bedrooms: 2 Septic Tank Size: 1000/500 gallons Trench Depth: 24 inch

# of Laterals: 3 Length of Each Lateral: 85 lineal feet Trench Width: 36 Inches

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the COSA, lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. It is the installers responsibility to ensure all required horizontal setbacks are met. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kathi J. Hooper, R.S.*

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:

This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.


Signed: Dallin Brinkley *Date:* 6/14/23

__✓__ Lincoln County Health Department (LCHD) ____ Licensed Installer w/ approval of LCHD

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

SV



D

res

E

cres

NO other wells or drainfield within 100 ft. of property boundaries other than shown