LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 09/18/2023 Expiration Date: 09/17/2024

Property Owner: Charles Waggoner

Mailing Address: [redacted]

Telephone: [redacted] E-mail: [redacted]

Installer: Kyle McNew License #: 199

Approved Work: (Check One) ☒ New Installation ☐ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Installation of new septic system.

Parcel Description:

Legal: LAKE CREEK RANCH PH1, S17, T30 N, R33 W, LOT 3, ACRES 3.53, PM 7156

Property Address: 44 Crow Ct. Troy, MT 59935 Assessment Code: 52738

DEQ COSA: EQ#11-1785 Date: 02/13/2014

Approved Design Criteria: Installation of new septic system with 4 laterals @ 100'.

# of Bedrooms: 3 Septic Tank Size: 1500 Trench Width: 24"

# of Laterals: 4 Length of Laterals: 100' Trench Depth: 24"-36"

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the COSA, lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. Reduction given for chambers. It is the installer's responsibility to ensure that all required horizontal setbacks are met. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: Robin Blumberg, S17

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:

This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.

Signed: Kyle w. McNew *Date:* 10/02/23

_____ Lincoln County Health Department (LCHD) _____ Licensed Installer w/ approval of LCHD

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

LOT 3 LAKE CREEK RANCH
MONTANA DEQ RE-WRITE COSA
WAGGONER LINCOLN COUNTY, MONTANA

PROPOSED SITE LAYOUT

ISSUED BY: JBM
ISSUED FOR: REVIEW
ISSUED ON: 07/29/2022
SHEET: 1

REVISION	DATE	MODIFICATION
1		
2		
3		

EVENSEN ENGINEERING & CONSULTING, INC. | (406) 885-4064 | WWW.EECIVIL.COM | EECI © 2022 | PROJECT NO. 22-035