LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 11/03/2023 Expiration Date: 11/02/2024

Property Owner: Janine Washburn

Mailing Address: [redacted]

Telephone: [redacted] E-mail: [redacted]

Installer: Bradley Persson License #: 159

Approved Work: (Check One) ☒ New Installation ☐ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Installation of new gravity system.

Parcel Description:

Legal: S19, T35 N, R25 W, COS 1568, PARCEL D, ACRES 1, OR TR 2B1 IN SENW

Property Address: Crystal Lakes Drive Assessment Code: 13021

DEQ COSA: EQ#27-87-S22-732 Date: 03/30/1987

pproved Design Criteria: Installation of new gravity system with 4 Laterals @ 48' with reduction given for chambers.

# of Bedrooms: 2 Septic Tank Size: 1000 gallon Trench Width: 24"

# of Laterals: 4 Length of Laterals: 48' Trench Depth: 24"-36"

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the COSA, lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. Reduction given for chambers. It is the installer's responsibility to ensure that all required horizontal setbacks are met. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: Robin Blumberg, S17

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:

This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.


Signed: Robin Blumberg *Date:* 12/18/23

___ Lincoln County Health Department (LCHD) ____ Licensed Installer w/ approval of LCHD

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

SV


N
Driveway
DBox
Well
House
T
R Zone
Communication & Electric Lines


Know what's below.
Tap, Click, or Call
811 Before you dig.
It's a Free Service!
APWA Uniform Color Code
For Marking Underground Utility Lines
White
Proposed Excavation
Pink
Temporary Survey Markings
Red
Electric Power Lines, Cables, Conduit and Lighting Cables
Yellow
Gas, Oil, Steam, Petroleum or Gaseous Materials
Orange
Communication, Alarm or Signal Lines, Cables or Conduit
Blue
Potable Water
Purple
Reclaimed Water, Irrigation and Slurry Lines
Green
Sewer and Drain Lines
In Montana, Call 811 or 800-424-5555
Two Business Days Before You Dig