SEPTIC TANK PERMIT
for
LINCOLN COUNTY

Permit Sent _____

Date 3-16-79

Phone [redacted]

Property Owner Jerry Woods Address [redacted]


Lot, Block Number, or legal description of Property Lot 28 Ponderosa Heights 2nd Add

To be built by: _____ Square feet absorption area. 400

Septic Tank Size 1000 gal # of bedrooms 4 Water Supply Well


Description of Absorption Area: Dig a ditch 200' long x 2½-3' deep x 2' wide according to ditch diagram and lot layout. Slope of pipe should not exceed a 1% drop.

Sketch; Must include property lines, buildings, and proposed septic tank-drainfield layout. Sketch must show distance from absorption area to wells, springs, streams, or lakes. Indicate depth of water table. Indicate slope.



DITCH DIAGRAM

LOT LAYOUT



SOIL: Silt-loam with cobbles

SLOPE: 2%

Issued by John W Patterson Inspected by _____

Date 3-16-79