LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
AFFIDAVIT OF WASTEWATER TREATMENT AND DISPOSAL SYSTEM COMPLIANCE REVIEW FOR SYSTEM INSTALLED, REPAIRED OR REPLACED WITHOUT A VALID PERMIT

Issue Date: 10/01/2022

Property Owner: Theodore Allers

Mailing Address: [redacted]

Telephone: [redacted] E-Mail: [redacted]

Who Installed System Being Reviewed: unknown Date Installed: December 2020

Type of System Work Reviewed:

__xx__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Use of System: Two bedroom house, second system on lot

Property Description:

Legal: S28 T37N R27W, Tr 2DB in SESW, 6.285 acres

Address or Location: 111 Valley View Rd, Eureka, MT 59917-9398

Reviewed System Components:

# of Bedrooms: 2	Septic Tank: 1000 gallons	Drainfield Construction: chambers
# of Laterals: 2	Length of Laterals: 100'	Trench Width: 24 inches

Comments: Gravity system using 1000 gallon tank and 2' wide trenches. Two laterals are each 100' long with chambers. Tank was pumped and filter cleaned 8/18/22 and reported to be in good condition. System is appropriately sized for wastewater flows of 300 gallons per day. Any future extension, repair, replacement or increase in wastewater flows must be reviewed and permitted by Lincoln County Health Department.

System Review Documentation Statement:

I, Kathi Hooper *, have reviewed the components of this system as listed above and found it to be in compliance with the requirements of A.R.M. Chapter 17.36 Subchapter 9, Circular DEQ-4 and Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: _____ *Date:* 10-1-22

Title: Director

NOTICE: This document is not a permit for installation, repair or alterations of a wastewater treatment and disposal system. It is a statement that the Department has conducted a review of this system and found it to be in compliance with applicable requirements, making it a legal system for the use described above. The Department does not guarantee that this system will continue to function properly for any period of time.


SV

111 VALLEY VIEW ROAD

6.285 ACRES
S28, T37M, R27W
ASSESSMENT 0000012920
GEO 56-4928-28-1-02-18-0000

DRAINFIELD SIZING


(2) BEDROOM= 225 GPD
225 GPD/0.6 APP= 376 SQFT
376 SQ FT/2' CHAMBERS= 188 LF
10% DEDUCTION FOR CHAMBERS= 170LF
170 LF/ 2 LATERALS= 85'
ACTUAL INSTALLED= (2) 100' LATERALS





D-BOX


START OF EAST LATERAL


END OF EAST LATERAL


PUMPED TANK OUTLET SIDE


END OF WEST LATERAL


START OF WEST LATERAL

TED ALLERS SITE MAP

REV	DESCRIPTION	BY/DATE	APPR/DATE

REV	DATE	COMPANY	SCALE		MONTANA DESIGN SERVICES
		MDS	1/16 = 1'-0"	ANSI B	ALLERS SEPTIC
		CONTRACT	DATE	SHEET REFERENCE	SITE LAYOUT
		VERBAL	7/2022		8/18/22
		PLOT FILE	WEIGHT		C. ALLERS 8/18/22
		PVA-0001			403-001 1

THE DESIGNS & PROPERTY OF MONTANA DESIGN SERVICES. ADDITIONS OR REVISIONS BETWEEN OWNER & MONTANA DESIGN SERVICES SHALL BE SUBMITTED TO ANY OTHER PARTIES WITHOUT WRITTEN APPROVAL FROM MDS RESPONSIBILITY