LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 04/22/2022 Expiration Date: 04/22/2023

Property Owner: Buckner, Randy c/o:

Address: [redacted]

Telephone: [redacted]

Installer: Self License No. N/A

XX New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: 1,500 gallon tank, gravity feed system. 3 laterals @ 65-feet for traditional trenches (perf pipe and drian rock) or 3 laterals @ 52-feet each for chambers (20% reduction for infiltration chambers) . This permit serves as an extension/reissue of the permit issued on 05/11/2016.

Parcel Description:

Legal: S26 T30 R31

Address or Location: Treasure View Estates Lot #5

Geo/Assessors code: 0000053519

Approved Design Criteria:

Bedrooms 3 Septic Tank Size: 1,500 gallon Drainfield Size: 195 / 156 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3,. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Nicholas Raines

Original Permit By: Jake Mertes, R.S.

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

Title: _____

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.
406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

LOT LAYOUT

