LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 05/18/2022 Expiration Date: 05/18/2023

Property Owner: Casazza, Rose c/o: Brad Persson

Address: [redacted]

Telephone: [redacted] [redacted]

Installer: Bradley Persson License No. 159

__XX__ New Installation ____ Existing System

____ Repair _____ Replacement ____ Extension ____ Other

Describe: 1,000-gallon septic tank with effluent filter. Gravity feed system with gravelless trenches (infiltration chambers). 3 laterals at 68-feet in length each.

Parcel Description:

Legal: S13, T36 N, R27 W, C.O.S. 4412, PARCEL A, ACRES 10

Address or Location: 80 Two Eagle Dr, Eureka, MT 59917

Geo/Assessors code: 0000059756

Approved Design Criteria:

Bedrooms: 3 Tank Size: 1,000 gallon Drainfield Size: 200 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Nicholas Raines

Closure Statement:

I, Miranda Davis *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Miranda Davis *Date:* 9/16/22

Title: Envir. Health Tech.

NOTICE: The Department must be notified at least 48 business hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.
406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

LOT LAYOUT