County

LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 8/9/2022 Expiration Date: 8/8/2023

Property Owner: Cameron Corder

Mailing Address: [redacted]

Telephone: [redacted] Email: [redacted]

Installer: Tom Cole License #: 1

Proposed Work: (Check One) ☒ New Installation ☐ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Gravity fed system with 2 chambers @ 70'

Parcel Description:

Legal: S29, T30 N, R33 W, C.O.S. 134363, PARCEL A, ACRES 6.767

Property Address: 400 Porcupine Creek Road Troy, MT 59935 Assessment Code: 14723

Approved Design Criteria:

# of Bedrooms: 3 Septic Tank Size: 1000 gallons Drainfield Size: 140 lineal feet

# of Laterals: 2 Length of Laterals: 70 lineal feet Trench Depth: 24-36 inches

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the COSA, lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. 25% reduction given for chambers. ANY CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: Kathi J. Hooper, R.S.

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:

This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.

Signed: Thomas J Cole *Date:* 9-28-22

_____ Lincoln County Health Department (LCHD) _____ Licensed Installer w/ approval of LCHD

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.


5

LOT LAYOUT

ZWEIFEL FAMILY TRANSFER

JUNE 1998

Lincoln County
EQ # 99-1005



LEGEND

- Soil Profile
- Percolation Site
- Proposed Septic Site and Replacement Site
- Slope
- Well Site

RECEIVED
JUL 02 1998
MT. DEPT. OF ENV. QUALITY
PERMITTING & COMPLIANCE DIV.

APPROVED
Montana Department of
Environmental Quality
Permitting and Compliance Division
Reviewer
7/8/98
Date

GRAPHIC SCALE

200 0 100 200 400 800

(IN FEET)
1 inch = 200 ft.