LINCOLN COUNTY
DEPARTMENT of ENVIRONMENTAL HEALTH
Wastewater Treatment and Disposal System
PERMIT

Contractor sign & return

Issue Date: 8-25-99 Expiration Date: 8-25-00

Property Owner: B.P. DEMPEWOLF

Address: [redacted]

Telephone: (Home) [redacted] (Work) _____

Installer: D.C. ORR License No. 17

_____ New Installation ✓ Existing System

_____ Repair ✓ Replacement _____ Extension _____ Other

Describe: _____

Parcel Description:

Legal: SW¼ S4 T30 R31 SHADY REST LOT 20

Address or Location: 397 Parmenter Drive

Approved Design Criteria:

Bedrooms 2 Septic Tank Size: 1000 gallons Drainfield Size: _____ lineal feet

INSTALL SYSTEM AS PER APPROVED SITE PLAN (LOT LAYOUT) AND LINCOLN COUNTY WASTEWATER REGULATION #3.

Special Instructions: Install 15'x25' leachbed w/ 12" washed sand below gravel

Issued By: Thomas Peterson, RS

Closure Statement:

I, DCOW *, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: [signature] *Date:* 8-27-99

Title: 17

NOTICE: ***The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.***

406-293-7781

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

Reconnect to New 2 Bedroom trailer after previous house burned. 05/09/23

Adin Delaney

For Charles Pope
406-871-6901