LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 3/21/2023 Expiration Date: 3/20/2024

Property Owner: Fortine School

Mailing Address: [redacted]

Telephone: [redacted] Email:

Installer: Koocanusa Plumbing, David Hull Jr. License #: 169

Proposed Work: (Check One) ☐ New Installation ☒ Existing System

☒ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Gravity system with 2' wide chambers, add 500 gallon tank at gym/cafeteria

Parcel Description:

Legal: S25 T35N R26W, Fortine Subd, Block 3, Lot 2 & 8, 2.7053 acres

Property Address: 358 Meadow Creek Rd, Fortine Assessment Code: 938

Approved Design Criteria: Gym/Cafeteria and School buildings

Max Discharge: 300 gpd Septic Tank Sizes: 1500 +1000 gallons Drainfield Size: 675 square feet

# of Laterals: 4 Length of Laterals: 84 lineal feet Trench Depth: 24 - 36 inches

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the COSA, lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. It is the installer's responsibility to insure that all required horizontal setbacks must be met. 10% reduction given for infiltrators. ANY CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kathi J. Hooper, R.S.*

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:

This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* 9-13-23

____ Lincoln County Health Department (LCHD) ____ Licensed Installer w/ approval of LCHD

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

Assessment Code _____

