LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 07/08/2022 Expiration Date: 07/08/2023

Property Owner: Jesse J. James

Mailing Address: [redacted]

Telephone: [redacted] Email:

Installer: License #:

Proposed Work: (Check One) ☒ New Installation ☐ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Install two 94' laterals, standard trenches, gravity flow,

Parcel Description:

Legal: S29, T31 N, R31 W, C.O.S. 4231, PARCEL C in SENE, ACRES 4

Property Address: 2577 KOOTENAI RIVER RD, Libby MT 59923 Assessment Code: 10793

Approved Design Criteria:

# of Bedrooms: 2 Septic Tank Size: 1000 gallons Drainfield Size: 188 lineal feet

# of Laterals: 2 Length of Laterals: 94 feet Trench Depth: 24-36 inches

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. ANY CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kathi J. Hooper, R.S.*

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

_____ Lincoln County Health Department (LCHD) _____ Licensed Installer w/ approval of LCHD

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

8

MURRAY BLA


SECTION 29-T31N-R31W
LINCOLN COUNTY

NO DRAINFIELDS/WELLS/APPROVALS (100FT)
OTHER THAN SHOWN (ALL SIDES)

EQ # 14-1910
Reviewed by the Local Reviewing Agent
Under contract with the
Department of Environmental Quality/ PCD
Local Reviewer — Date 9/9/13

Accepted under contract
Janet Skaarland 9/16/13
DEQ Representative — Date

Jere Johnson, R.S
Environmental Health Consulting
4572 Whitefish Stage Road
Whitefish MT 59937



RECEIVED
SEP 12 2013
MT DEQ PUBLIC WATER
& SUBDIVISION BUREAU

LEGEND

- PRIMARY / REPLACEMENT DRAINFIELD
- △ PROPOSED WELL
- ■ TEST HOLE
- ● PERC TEST
-) DETENTION SWALE

N

1" = 200'

PARCEL A & C
38 ft X 3ft X 1ft retention/detention basin below building site or in natural topographical low, and 3ft wide X 1ft deep with 3:1 slopes ditch along both sides of driveway.

NOTE:
ALL STORMWATER SHALL BE RETAINED ON THE PROPERTY.
DRIVEWAY AND BUILDING CONSTRUCTION MUST BE COMPLETED SUCH THAT RUNOFF WILL NOT FLOW OFF PROPERTY.

OWNER OF THE PROPERTY IS THE RESPONSIBLE ENTITY FOR THE MAINTENANCE OF THE STORMWATER STRUCTURES

DRAINFIELD SIZING:
DEQ = 0.6gpdpsf
300/0.6 = 500sf
500sf/2 = 250lf/3 = 3-83ft laterals
Proposed: 3-83ft laterals, 7ft centers, 3ft trench depth