LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 12/23/2022 Expiration Date: 12/22/2023

Property Owner: Thomas Johnson

Mailing Address: [redacted]

Telephone: [redacted] E-mail: [redacted]

Installer: Kyle McNew License #: 199

Approved Work: (Check One) ☒ New Installation ☐ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Gravity system with standard 2' wide trenches reduction for chambers

Parcel Description:

Legal: Cabinet Vista Estates Phase 2, Lot 12, S06 T29N R33w, 5.02 acres

Property Address: 380 North Spur Dr. Troy, MT Assessment Code: 52590

DEQ COSA: EQ# Date:

Approved Design Criteria:

# of Bedrooms: 3 Septic Tank Size: 1000gallon Trench Width: 24"

# of Laterals: 3 Length of Laterals: 88 Trench Depth: 24"-36"

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the COSA, lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. Reduction given for chambers. It is the installer's responsibility to ensure that all required horizontal setbacks are met. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kathi Hooper, RS*

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:

This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.


Signed: _____ *Date:* 9/22/23

✓ Lincoln County Health Department (LCHD) ____ Licensed Installer w/ approval of LCHD

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

Johson Septic



Scanned with CamScanner