LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 9/13/2022 Expiration Date: 9/12/2023

Property Owner: Robert & Annette LaFata

Mailing Address: [redacted]

Telephone: [redacted] Email: [redacted]

Installer: Homeowner – Requires Inspection License #: NA

Approved Work: (Check One) ☒ New Installation ☐ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Gravity system, standard 2' wide trenches, perf pipe and drain rock

Parcel Description:

Legal: Swede Bluff Estates, Lot 1 S25 T30N R31W, 5.741 acres

Property Address: 1516 Swede Mountain Rd, Libby Assessment Code: 13154

Approved Design Criteria:

Residential: 475 gpd Septic Tank Size: 2000 gallons Drainfield Size: 950 square feet

# of Laterals: 5 Length of Laterals: 95 lineal feet Trench Depth: 24 inches

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the COSA, lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kathe J. Hooper, R.S.*

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:


This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date* 8-22-23

____ Lincoln County Health Department (LCHD) ✓ Licensed Installer w/ approval of LCHD

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.


Transformer
meter
well
House
400'
Shop
30 x 50
Septic Tank
Sevier Dr
Mountain Rd