

**LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT**

Issue Date: 11/01/2022

Expiration Date: 10/31/2023

Property Owner: Robert Ladesich

Mailing Address: [REDACTED]

Telephone: [REDACTED]

Email: [REDACTED]

Installer: TBD (Licensed Installer Required)

License #:

Approved Work: (Check One)

☒ New Installation

☐ Existing System

☐ Replace Drainfield

☐ Replace Tank

☐ Extension

Describe: Pressure dosed, elevated sand mound system using 3' chambers per EQ 08-2791

Parcel Description:

Legal: Fisher River Retreat, Lot 3B, S30 T27N R29W, 6.17 acres

Property Address: 10 Either Way N, Libby

Assessment Code: 56178

Approved Design Criteria:

of Bedrooms: 3

Septic Tank Size: 1000/500 gallons

Trench Width: 36" chambers

of Laterals: 2

Length of Laterals: 56 feet

Trench Depth: NA

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. ANY CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: *Kathi J. Hooper, R.S.*

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.

Signed: _____

Date: _____

____ Lincoln County Health Department (LCHD)

____ Licensed Installer w/ approval of LCHD

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

SV

LINCOLN COUNTY, MONTANA
 LOT LAYOUT
 FISHER RIVER RETREAT
 IN THE E1/2 OF SECTION 30 AND
 THE W1/2 NW1/4 OF SECTION 29,
 TWP. 27 N., R. 29 W., P.M.M.
 FOR: JACOBY DEVELOPMENT, L.L.C. DATE: JANUARY 2008

EQNO
 08-2771
 KED-

- LEGEND**
- SOILS PROFILE
 - PERCOLATION SITE
 - PROPOSED WELL SITE
 - PROPOSED BUILDING SITE
 - 1,500 GALLON SEPTIC TANK
 - SLOPE
 - GRADIENT DIRECTION
 - PROPOSED SEPTIC SITE
2-56' TRENCHES
7' APART
 - REPLACEMENT SITE
2-56' TRENCHES
7' APART
 - - - 100' MIXING ZONE

Reviewed by the Local Reviewing Authority
 Under contract with the
 Department of Environmental Quality/BCD
Barbara Kingery 11/14/2008
 Local Reviewer Date

Accepted under contract
Barbara Kingery 11/19/08
 DEQ Representative Date

NO WELLS OR
 SEPTICS WITHIN
 100' OF PROPERTY
 BOUNDARIES

ELEVATED SAND MOUND SYSTEM
 2-56' TRENCHES
 7' APART

INDIVIDUAL HOMEOWNERS
 ARE RESPONSIBLE FOR THE
 MAINTENANCE OF STORMWATER
 STRUCTURES WITHIN THE PRIVATE
 DRIVEWAYS AND TO OBTAIN
 A FLOOD PLAIN PERMIT FROM
 LINCOLN COUNTY

