LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 10/25/2022 Expiration Date: 10/25/2023

Property Owner: Eric Lowell

Mailing Address: [redacted]

Telephone: Email:

Installer: Quality Excavation License #: 166

Approved Work: (Check One) ☒ New Installation ☐ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Gravity system w (3) 100' laterals , 2' wide trenches, drain rock & pipe.

Parcel Description:

Legal: DENEGAL, S21, T37 N, R27 W, Lot 5, ACRES 6.422, PM 7123

Property Address: COWGIRL CV EUREKA MT 59917 Assessment Code: 55795

Approved Design Criteria:

# of Bedrooms: 3	Septic Tank Size: 1000 gallons	Trench Width: 24 inches
# of Laterals: 3	Length of Laterals: 100 feet	Trench Depth: 24-36 inches

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. 10% reduction given for chambers. ANY CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: Kathi J. Hooper, R.S.

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:

I, Kurt West *, have inspected this system and found it to be in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.*

Signed: Kurt West *Date:* 10/25/2023

_____ Lincoln County Health Department (LCHD) _____ Licensed Installer w/ approval of LCHD


DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

SV

LOT

DENE
GOV'T LOT 3, SEC
FOR CHARLE



LINE	BEARING	DISTANCE
L1	S80°21'25"W	97.68'
L2	S59°43'54"W	108.69'
L3	S68°39'12"W	89.96'
L4	S89°54'19"W	194.73'
L5	N30°26'59"W	75.00'
L6	N18°46'26"E	83.89'
L7	N54°52'66"E	90.43'
L8	N65°01'23"E	116.01'
L9	N34°51'18"E	286.55'
L10	N42°28'09"E	84.94'

LINE	BEARING
L11	N56°05'55
L12	N66°28'00
L13	N66°28'00
L14	N70°08'20
L15	N83°24'35
L16	S18°41'34
L17	S08°18'67
L18	S13°13'33
L19	S73°24'03

SAM CORDI
REGISTERED LAND SURVEYOR
974 COLORADO AVE.
P.O. BOX 323
WHITEFISH, MT 59937
PHONE: (406)-862-9977