LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 10/10/22 Expiration Date: 10/9/2023

Property Owner: Gerry & Kim Mercer

Mailing Address: [redacted]

Telephone: [redacted] E-mail:

Installer: Homeowner (requires inspection) License #: NA

Approved Work: (Check One) ☒ New Installation ☐ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Install new gravity system with chambers, standard 2' wide gravelless trenches

Parcel Description:

Legal: Twin Creek View, Lot 2, S20 T30N R33W, 22.64 acres

Property Address: 359 Twin Creek Dr, Troy, MT Assessment Code: 14625

Approved Design Criteria:

# of Bedrooms: 3	Septic Tank Size: 1000 gallons	Trench Width: 24 inches
# of Laterals: 3	Length of Laterals: 85 lineal feet	Trench Depth: 24-36 inches

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the COSA, lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. 15% reduction allowed for chambers. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: Kathi J. Hooper, R.S.

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:

This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.


Signed: Miranda Davis - Envir. Health Tech *Date:* 10/19/22

_X_ Lincoln County Health Department (LCHD) _____ Licensed Installer w/ approval of LCHD

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

5


10½
5'
7'
3'
5'
5'
5'
92 ft
92 ft
100 ft
104 ft
Well
75ft