sign + retur

LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 06/01/2022 Expiration Date: 05/30/2023

Property Owner: Michelle & Scot Munson c/o:

Address: [redacted]

Telephone: (Home) (Work)

Installer: Mountain Contracting License No. 3

Proposed Work: (Check One) ☐ New Installation ☒ Existing System

☐ Repair ☒ Replacement ☐ Extension ☐ Other _____

Describe: Two 75 foot laterals, gravity flow, standard trenches

Parcel Description:

Legal: S5 T35N R27W, COS 2661, Parcel A

Address or Location: 6198 Pinkham Creek Rd, Rexford

Approved Design Criteria:

Bedrooms: 2 Septic Tank Size: 1000 gallon Drainfield Size: 150 lineal feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Kathi J. Hooper, R.S.

Closure Statement:

I, Richard Luciano, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: _____ *Date:* 6/7/2022

Title: Installer

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

Well
120'
Old System To be Abandoned
500 gal
Main line
Electric Service Pole
6" Slope
45°
Clean Out
House
New Tank 1000
10'
A. Box
75'
Two Seventy Five Foot Trenches
75'
Replacement Area
Home Stead Drive 60' From Replacement Area
6" Slope
Shop
No Environments
Drive way
N