LINCOLN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 7/20/2022 Expiration Date: 7/20/2023

Property Owner: Cam Sherwood

Mailing Address: [redacted]

Telephone: Email:

Installer: Glacier Excavating License #: 141

Proposed Work: (Check One) ☒ New Installation ☐ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Install (3) 75' chambers with drain rock

Parcel Description:

Legal: GATEWAY VILLAGE UNIT 7, S03, T37 N, R27 W, Lot 27, ACRES 5.029

Property Address: Aspen Lane Lot 27 Assessment Code: 17997

Approved Design Criteria:

# of Bedrooms: 3 Septic Tank Size: 1000/500 gallons Drainfield Size: 225 Lineal feet

# of Laterals: 3 Length of Laterals: 75 lineal feet Trench Depth: 24-36 inches

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!

Special Instructions: Install system according to the COSA, lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. ANY CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.

Issued By: Kathi J. Hooper, R.S.

NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

Closure Statement:


This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.

Signed: Kathi Hooper, RS *Date:* 7/29/22

X Lincoln County Health Department (LCHD) ____ Licensed Installer w/ approval of LCHD

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.


N
well
power vault
Driveway
water line
power line
House
perc test hole
1000/500 septic tank
Aspen Drive - Gateway Village
660'