LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 06/01/2022 Expiration Date: 6/01/2023

Property Owner: Daryl Smith c/o:

Address: [redacted]

Telephone: (Home) (Work)

Installer: A-1 Outback Construction License No. 96

__xx__ New Installation ___ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Four 64' laterals using gravelless chambers. Size reduced per 0.4 app. rate.

Drainfield size reduced from 3 bedroom to 2 on 7/19 - JH

Parcel Description:

Legal: S26 T36 R26

Address or Location: Stonegate Lot 8

Geo/Assessors code: 0000054660

Approved Design Criteria:

Bedrooms 2 Septic Tank Size: 1000 gallons Drainfield Size: 253 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Kathi Hooper, R.S.

Closure Statement:

I, Dustin Webb *, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Dustin Webb, RS *Date:* 08/08/22

Title: Registered Sanitarian


NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly

Stonegate Sub. Lot 8
S 26 T 36 N R 26 W



1" = 100'

N