# LINCOLN COUNTY HEALTH DEPARTMENT
# ENVIRONMENTAL HEALTH
# WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 9/11/2022 Expiration Date: 9/10/2023

Property Owner: Snow Shoe Ranch LLC

Mailing Address: [redacted]

Telephone: Email:

Installer: Tally Hoe License #: 1

Proposed Work: (Check One) ☒ New Installation ☐ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Gravity system, standard 2' wide trenches, chambers

*Parcel Description:*

Legal: S10 T29N R31W, 169.99 acres

Property Address: 324 No Creek Rd, Libby Assessment Code: 2380

*Approved Design Criteria:*

# of Bedrooms: 2 Septic Tank Size: 1000 gallons Drainfield Size: 750 square feet

# of Laterals: 4 Length of Laterals: 96 lineal feet Trench Depth: 24 inches

**SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!**

*Special Instructions: Install system according to the COSA, lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.*

**Issued By:** *Kathi J. Hooper, R.S.*

**NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.**

Closure Statement:


*This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.*

*Signed:* _____ *Date:* _____

_____ Lincoln County Health Department (LCHD) X Licensed Installer w/ approval of LCHD

***DISCLAIMER***

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.


Beck Rd
N
A
Replace ment
96'
RV
RV
2 Bedroom
over 150Yd
pond