LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 7/28/2022

Expiration Date: 7/28/2023

Property Owner: Dale Strodtbeck

1st Permit Issued : 06/06/2018

Address: [redacted]

Telephone: (Home)

(Work)

Installer: MDS

License No. 135

xx New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Two 70' laterals using gravelless chambers. Size reduced per 0.8 app rate.

Parcel Description:

Legal: S14 T37 R27

Address or Location: AJ Estates Lot 7

Geo/Assessors code: 0000054434

Approved Design Criteria:

Bedrooms 2 Septic Tank Size: 1000 gallons Drainfield Size: 140 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Kathi Hooper, R.S.

Closure Statement:

I, Buck Schermerhorn have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: [signature] Date: 8/16/22

Title: President

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.




DRAINFIELD LOCATION

PINE CREEK LANE

REPLACEMENT ZONE

(3) 80' LONG LATERALS GRAVITY SYSTEM

15.3'



(3) 48' LATERALS

WELL

GARAGE

DRIVEWAY

LUCIANO DRIVE

POWER/PHONE

1000/500 SEPTIC TANK

100' WELL SETBACK

(2) BEDROOM HOUSE

WATER LINE

PROPERTY LINE

AIRPORT PROPERTY

LOT 7

2.31 ACRES
S14, T37N, R27W
PM 6477, E.Q. 02-1071
AJ ESTATES
GEO 56-4928-14-2-03-29-0000



LATERAL INSTALLATION

DRAINFIELD SIZING

(2) BEDROOM= 80'/BEDROOOM= 160' PER COSA
GROUND HAS A 0.8 APP RATE PER COSA NUMBERS
25% REDUCTION IN DRAINFIELD SIZE AT 0.8 FOR USE OF CHAMBERS
160' X 0.75= 120' LATERALS REQUIRED
(3) LATERALS INSTALLED AT 48' EACH= 144'

STRODBECK SITE MAP

REV.	DATE	COMPANY	SCALE
		D/H	1"=5' H, NOTED
		CONTRACT	DATE: 6/2022
		VERBAL	
		PLOT FILE	WEIGHT
		PVE_0001	

D & HAULING
STRODBECK SEPTIC PERMIT
SITE LAYOUT
DRAWN BY: 6/15/22
D. PLUIS 6/15/22
STRODBECK 1

THIS DRAWING IS PROPERTY OF DAN HAUL ECHNICT WAS SEEN TO/SIGNED WITHOUT WRITTEN APPROVAL FROM DAN'S HAULING

8 5 4 3 2