sign + return

# LINCOLN COUNTY HEALTH DEPARTMENT
# ENVIRONMENTAL HEALTH
# WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 08/26/2022 Expiration Date: 08/25/2023

Property Owner: Rocky & JoAnn Sutherland

Mailing Address: [redacted]

Telephone: Email:

Installer: Tally Hoe License #: 1

Proposed Work: (Check One) ☒ New Installation ☐ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Standard 2' wide trenches, gravity system, 10% reduction for chambers

*Parcel Description:*

Legal: S28 T32N R29W, COS 759, 29.94 acres

Property Address: 11905 FDR Rd, Libby, MT Assessment Code: 10862

*Approved Design Criteria:*

# of Bedrooms: 2 Septic Tank Size: 1000 gallons Drainfield Size: 504 square feet

# of Laterals: 3 Length of Laterals: ~~84~~ 100' feet Trench Depth: 24 inches

**SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!**

*Special Instructions: Install system according to the lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, and Circular DEQ-4. ANY CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.*

**Issued By:** *Kathi J. Hooper, R.S.*

**NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.**

Closure Statement:


*I,* Thomas J Cole *, have inspected this system and found it to be in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.*

*Signed:* Thomas J Cole *Date:* 9-7-22

____ Lincoln County Health Department (LCHD) _X_ Licensed Installer w/ approval of LCHD

***DISCLAIMER***

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.


Barton Cr Rd
N
Slope 2%
well
3 Bed
40'
10
3 @ 100'
F D R rd.
Barton Creek