LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 12/17/2021 Expiration Date: 12/17/2022

Property Owner: Traenkner, Barbara T. c/o: Traenkner, Ronald Jr.

Address: [redacted]

Telephone: [redacted] [redacted]

Installer: Terry Oedewalt License No. 002

__XX__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other- Renewal (MD)

Describe: 1,000 gal tank / 500 gal pump tank (pumped to gravity feed drainfield). Gravelless (chambers) with 3 laterals @ 95 lineal feet each. *(includes 15% reduction for use of infiltrators and 0.5 gpd/ft2 application rate)*

Parcel Description:

Legal: EAGLE COVE, S18, T31 N, R33 W, ACRES 4.02, LOT 12 PM 6341

Address or Location: 107 Swiftwater Ln., Troy, MT 59935

Geo/Assessors code: 0000053737

Approved Design Criteria:

Bedrooms: 3 Septic Tank Size: 1,000 gal / 500 gal pump tank Drainfield Size: 285 Lineal Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Nicholas Raines

Closure Statement:

I, TERRY OEDEWALDT, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: _____ *Date:* 1/26/2022

Title: PRESIDENT

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

PLANNED SEPTIC 2021

