LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 05/18/2022 Expiration Date: 05/18/2023

Property Owner: Yoder, Rhoda c/o: Ivan Miller

Address: [redacted]

Telephone: [redacted]

Installer: Ivan Miller License No. 52

XX New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: 1,000-gallon septic tank + 500 gallon pump chamber (cabin), 1,000 gallon tank (garage), and effluent filter. Gravity feed system with gravelless trenches (infiltration chambers), 4 laterals at 80-feet in length each.

Parcel Description:

Legal: S15, T37 N, R28 W, C.O.S. 4154, PARCEL B, ACRES 2.06

Address or Location: West Kootenai, Rexford, MT 59930

Geo/Assessors code: 0000055836

Approved Design Criteria:

Bedrooms: 2 (house) + bath (garage) Tank Size: 1,000 gallon + 500 gallon pump chamber + 1,000 gallon tank (garage) Drainfield Size: 320 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Nicholas Raines

Closure Statement:

I, Ivan Miller, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Ivan Miller *Date:* 7-11-2022

Title: installer

NOTICE: The Department must be notified at least 48 business hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

We would prefer to install Garage in same drainfeild if possible

