# LINCOLN COUNTY HEALTH DEPARTMENT
# ENVIRONMENTAL HEALTH
# WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 04/29/2025 Expiration Date: 04/28/2026 Permit# 25-54697

Property Owner: Michelle Alm

Mailing Address: [redacted]

Installer: Bubba Persson License #: 197

*Approved Work:* (Check One) ☒ New Installation ☐ Existing System

☐ Replace Drainfield ☐ Replace Tank ☐ Extension

Describe: Installation of new pressure dosed system for 3 Bedroom House.

Legal: GLEN LAKE HILLS, S27, T36 N, R26 W, ACRES 2.49, LOT 3 PM 6749

Property Address: Evergreen Dr., Eureka, MT 59917 Assessment Code: 54697

DEQ COSA: EQ#06-3180 Date: 11/28/2006

*Approved Design Criteria:* Installation of new pressure dosed system for 3 Bedroom House with 4 Laterals @ 64'.

# of Bedrooms: 3 Septic Tank Size: 1000/500 Gallon Trench Width: 36"

# of Laterals: 4 Length of Laterals: 64' Trench Depth: 24"-36"

**SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET!!**

*Special Instructions: Install system according to the Lot layout, the Lincoln County Wastewater Treatment and Disposal Regulation, Circular DEQ-4, and COSA(if applies). It is the installer's responsibility to ensure that all required horizontal setbacks are met. CHANGES MUST BE PRE-AUTHORIZED BY THE DEPARTMENT.*

**Issued By:** *Robin Blumberg, RS*

**NOTICE: The Department must be notified at least 3 business days (72 hours) prior to backfilling the system. Call 406-283-2442. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation Ch. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.**


Closure Statement:

*This system is in compliance with the approved design criteria and Lincoln County's Wastewater Treatment and Disposal Regulation.*

*Signed:* Robin Blumberg *Date* 6/16/25

***This permit is not finalized until the system is inspected and the closure statement is signed.***

***This permit is not a guarantee that the system will function properly for a prescribed period of time.***




ALM SITE LAYOUT

## DRAINFIELD SIZING

(3) BEDROOM= 300 GPD
300 GPD/0.4 APP= 750 SQFT
750 SQ FT/3' CHAMBERS= 250 LF
250 LF/ 4 LATERALS @ 64'

## LOT 3

2.49 ACRES
EVERGREEN DRIVE, EUREKA, MT 59917
S27, T36N, R26W, GLEN LAKE HILLS, PM6749
ASSESSMENT #0000054697
GEO 56-4824-27-2-01-40-0000
COSA 06-3180, DATED 11-2006

| REV | DESCRIPTION | BY | DATE | APPD | DATE |
|---|---|---|---|---|---|

| REV | DATE | COMPANY | SCALE: | SUBBA'S EXCAVATION ALM SEPTIC |
|---|---|---|---|---|
| | | MDS | 1/16 = 1'0" | SITE LAYOUT |
| | | CONTRACT: | DATE: | 4/2/25 |
| | | VERSAL | 2/2025 | |
| | | PLOT FILE: | WEIGHT: | B. PERSON 4/2/25 |
| | | FWL-0001 | FINISH | 406-001 1 |

THIS DRAWING IS PROPERTY OF MDS, INC. CONTRACT AND SHOW RELEASED WITHOUT OWNER & MDS IT CAN NOT BE SUBMITTED TO ANY OTHER PARTIES WITHOUT WRITTEN APPROVAL FROM MDS MANAGEMENT