County

LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 05/13/2021

Expiration Date: 05/13/2022

Property Owner: Keith & Mindy Andresen

c/o:

Address: [redacted]

Telephone: [redacted] (Home)

(Work)

Installer: Keith Mack

License No. ///

RECEIVED
DEC 2 1 2021
BY: AR

__XX__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Four 100' laterals using drain rock & perf pipe.

Parcel Description:

Legal: CABINET VISTA ESTATES PH 2, S06, T29 N, R33 W, ACRES 5, LOT 7 PM 6872

Address or Location: LOT 7

Geo/Assessors code: 0000052581

Approved Design Criteria:

Bedrooms: 5 Septic Tank Size: 1500 gallons Drainfield Size: 400 Lineal Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Keith Mack, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Keith Mack *Date:* 6-25-21

Title: Mack Excavating

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

Not to Scale
318.80'
TOTAL: 350.70'
S00°14'21"W
290.10'
500 gallon Septic Tank
60'
100'
20'
House
LOT 7
Drive way
Septic to Well 230'
+ Well
S56°40'58"W
RADIAL
L54
L53
SEE DETAIL
L64
L63
L62
SHORT DRIVE
25'
Culvert