County

LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 09/10/2021 Expiration Date: 09/10/2022

Property Owner: Stewart Ator c/o:

Address: 15 West Side Pipe Creek Rd., Libby, MT 59923

Telephone: (Home) (Work)

Installer: Tallyhoe License No.: 1

Proposed Work: (Check One) ___ New Installation ___ Existing System

___ Repair __XXX__ Replacement ___ Extension ___ Other

Describe: 2 Laterals @ 54' and 1000 Gallon Septic Tank

Parcel Description:

Legal: S14 T32N R31W

Address or Location: 15 West Side Pipe Creek Rd., Libby, MT 59923

Approved Design Criteria:

Bedrooms: 2 Septic Tank Size: 1000 gallons Drainfield Size: 108 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Dustin Webb, RS

Closure Statement:

I, Thomas J Cole, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Thomas J Cole *Date:* 9-18-21

Title: owner/operator

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

RECEIVED
OCT 04 2021
BY:

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

