LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 09/28/2021 Expiration Date: 09/08/2022

Property Owner: Jason Campbell c/o:

Address: [redacted]

Telephone: [redacted] (Home) (Work)

Installer: Koocanusa Excavating, LLC License No.: 135

Proposed Work: (Check One) XXX New Installation ___ Existing System

___ Repair ___ Replacement ___ Extension ___ Other

Describe:

Parcel Description:

Legal: S05 T35N R27W, Parcel B, COS 2661

Address or Location: 6225 Pinkham Creek Rd., Eureka, MT 59917

Assessment #: 0000014799

Approved Design Criteria: 1000/500 pressure-dosed system and 3 40' laterals

Bedrooms: 3 Septic Tank Size: 1000/500 gallons Drainfield Size: 120 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Dustin Webb, RS

Closure Statement:

I, Buck Schermerhorn have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.


Signed: [signature] Date: 9/1/21

Title: President


NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-293-2443

NORTH



8' TEST HOLE



TEST HOLE



SPOILS PILE

TEST HOLE GRADIENT


0"–6" TOP SOIL
6"– 18" SANDY SILT
18"– 96" 4"–6" ROCKS AND SILT
0.4 APP RATE– SAND MOUND TO BE USED BECAUSE OF SPACE LIMITATIONS



PARCEL B

23.76 ACRES
S05, T35N, R27W
COS 2661
GEO 56–4716–05–1–01–04–0000

OVERALL SITE LAYOUT



HOUSE SITE LAYOUT

CAMPBELL SITE LAYOUT

REV	DATE	COMPANY	SCALE:	HOOCANUSA EXCAVATING CAMPBELL SEPTIC
		KEI	1/16 = 1'0"	SITE LAYOUT
		CONTRACT:	DATE:	6/23/21
		VERSUS	6/2021	S. MCNAMARA 6/23/21
		PLOT FILE:	WEIGHT:	219-001 1
		PNL-0001		

THIS DRAWING IS PROPERTY OF KEI LAND CONTRACT AND SHALL NOT BE REPRODUCED, COPIED OR USED IN ANY MANNER WHATSOEVER WITHOUT THE EXPRESS WRITTEN PERMISSION OF KEI LAND CONTRACT.