LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 06/08/2021

Expiration Date: 06/08/2022

Property Owner: Lanti Carlson

c/o:

Address: [redacted]

Telephone: [redacted] (Home)

(Work)

Installer: Shane Nelson

License No. 118

RECEIVED
NOV 10 2021
BY:

__XX__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Two 94' pressure dosed in 3' side trenches.

Parcel Description:

Legal: PINES AT FISHER RIVER, S13, T27 N, R28 W, ACRES 6.11, PM 6807 LOT 7

Address or Location: LOT 7

Geo/Assessors code: 0000055033

Approved Design Criteria:

Bedrooms: 2 Septic Tank Size: 1000/500 gallons Drainfield Size: 188 Lineal Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, SHAYNE NELSON, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Shayne Nelson *Date:* 10/12/2021

Title: Nelson Excavating LLC


NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

LOT LAYOUT



Dept of Health
418 Mineral Ave
Libby, MT 59923