LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 06/09/2021 Expiration Date: 06/09/2022

Property Owner: Karen Carter & Bud Lavery c/o:

Address: [redacted]

Telephone: [redacted] (Home) (Work)

Installer: Unknown at time of App. Review License No. #178
Kootenai County Construction

__XX__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Three 75' laterals.

Parcel Description:

Legal: EUREKA HILLS PH 2, S26, T36 N, R27 W, ACRES 2.935, LOT 39 PM 6904

Address or Location: LOT 39

Geo/Assessors code: 0000055366

Approved Design Criteria:

Bedrooms: 2 Septic Tank Size: 1000 gallons Drainfield Size: 225 Lineal Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, Zayne Davis, *have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: [signature] *Date:* 08/03/2021

Title: Owner operator Kootenai county construction license #178

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

SITE PLAN

New Residence For:

Bud Lavery
Karen Carter

Another Quality Project by:

Built Right in Montana (406)270-0317

Project: Carter/ Lavery	Sheet: S-1
Date: 03/17/2021	
Scale: 1' = 1/4"	