LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 08/23/2021 Expiration Date: 08/23/2022

Property Owner: Ian Caswell c/o:

Address: [redacted]

Telephone: [redacted] (Home) (Work)

Installer: Dallas Pluid (inspected by MDS) License No. 135

__XX__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Three 85' laterals using gravity system with 2' wide infiltrator galleries.

Parcel Description:

Legal: S21, T36 N, R27 W, CS #3288, PARCEL N/A, TR 3 IN S2NW CS #3288 37.099 ACRES

Address or Location: 363 Lupus Lane Rexford, MT 59930

Geo/Assessors code: 0000054478

Approved Design Criteria:

Bedrooms 2 Septic Tank Size: 1000/500 gallons Drainfield Size: 255 Lineal Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Jake Mertes, R.S.

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

Title: _____

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.


406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.



CASWELL LOT LAYOUT



CASWELL SITE LAYOUT

REV	DESCRIPTION	BY/DATE	APPR/DATE

REV	DATE	COMPANY	SCALE:	MONTANA ARCHIVE SERVICES, INC.	D&H HAULING CASWELL SEPTIC PERMIT
		MDS	1/16 & NOTED		SITE LAYOUT
		CONTRACT:	DATE:	DWG TOLERANCES:	7/13/21
		VERBAL	11/20		7/13/21
		PLOT FILE:	WEIGHT	FINISH	CASWELL-UP
		PML-0001	---		1

THIS DRAWING IS PROPERTY OF MDS UNDR CONTRACT HAS BEEN SECURED BETWEEN OWNER & DALLAS PLUD IT CAN NOT BE SUBMITTED TO ANY OTHER PARTIES WITHOUT WRITTEN APPROVAL FROM MDS MANAGEMENT

6 5 4 3 2