County

LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 11/012/2021 Expiration Date: 11/012/2022

Property Owner: Chen, Qiuyon c/o: Panda Chinese Restaurant

Address: 31312 US Highway 2 Libby, MT 59923

Telephone: [redacted] (Work)

Installer: Tally Hoe License No. 1

___ New Installation ____ Existing System

____ Repair __XX__ Replacement ____ Extension ____ Other- Renewal (MD)

Describe: Gravity system with 1,000 gallon septic tank. Graveless with 3-feet wide chambers/infiltrators. 2 laterals @ 70 lineal feet each for a total absorption area of 140 square feet.

Parcel Description:

Legal: S33, T31 N, R31 W, ACRES 1, TR-35ADA2 & 3FBCA SWSW

Address or Location: 31312 US Highway 2 Libby, MT 59923

Geo/Assessors code: 0000010004

Approved Design Criteria:

Bedrooms: N/A (commercial) Septic Tank Size: 1000 gallons Drainfield Size: 140 Lineal Feet

Special Instructions:

INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Kathi Hooper, R.S.

Closure Statement:

I, Thomas J Cole *, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Thomas J Cole *Date:* 11-13-21


Title: owner operator

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.


Hwy 2 ← west
N
Soil
small rock
Sand
restaurant
B
7'
10'
?
old
old system
70'
water?
line
10'