LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 11/17/2021

Expiration Date: 11/17/2022 (RENEWAL)

#1694

Property Owner: Dorothy Eisenman

c/o: Brad Persson

Address: Eureka, MT 59917

Telephone: (Home)

(Work) [redacted]

Installer: Brad Persson

License No. 159

__XX__ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension __XX__ Other (RENEWAL)

Describe: Five 96' Laterals using chambers.

Parcel Description:

Legal: CYHAWK ESTATES, S29, T36 N, R27 W, ACRES 11.367, LOT 8 PM 7174

Address or Location: LOT 8

Geo/Assessors code: 0000059710

Approved Design Criteria:

Bedrooms 4 Septic Tank Size: 1500 gallons Drainfield Size: 480 Lineal Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Kathi Hooper, R.S.

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

Title: _____

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

LOT LAYOUT

