LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 03/26/2021 Expiration Date: 03/26/2022

Property Owner: Lety Frey c/o:

Address: [redacted]

Telephone: [redacted] (Home) (Work)

Installer: Elmer Brenneman License No. 170

___XX___ New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Three 62.5' chambers.

Parcel Description:

Legal: SUNSET RIDGE, S10, T36 N, R27 W, Lot 1, ACRES 1.47, PM 6291

Address or Location: LOT 1

Geo/Assessors code: 0000053862

Approved Design Criteria:

Bedrooms: 3 Septic Tank Size: 1000 gallons Drainfield Size: 187.5 Lineal Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Jake Mertes, R.S.*

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____ *Date:* _____

Title: _____

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

DISCLAIMER


This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

Frey

Legend

- proposed drainfield site
- proposed replacement area
- proposed well site w/ 100' isolation
- mixing zone

Name: Re-review of LOT 1 of EQ#00-2163
County: Lincoln
Location: NENE1/4 sec.10-T36N-R27W
E.Q.# 21-1559



Reviewed by the Local Reviewing Authority
Under contract with the
Department of Environmental Quality

Local Reviewer 11/13/20 Date

Accepted under contract

Janet Skoorland 11/23/20
DEQ Representative Date

RECEIVED
NOV 17 2020
MT DEQ

N

1" = 100'

Enviro-Tech
Consulting Inc.
Brian S. Launius
PO Box 5674
Kalispell, MT 59903
(406)257-2795