

**LINCOLN COUNTY  
DEPARTMENT OF ENVIRONMENTAL HEALTH  
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT**

Issue Date: 10/21/2021

Expiration Date: 10/21/2022

Property Owner: KLMNO LLC

c/o: Andy & Jen Mefford

Address: [REDACTED]

Telephone: [REDACTED]

(Work)

Installer: TBD-Will be a certified Installer

License No. 56

XX New Installation

       Existing System

       Repair        Replacement        Extension        Other- Renewal (MD)

Describe: 3" Wide chambers and pressure dosed.

*Parcel Description:*

Legal: S30, T36 N, R26 W, ACRES 44.818, CS 390 OR TR 5D CS 375

Address or Location: TR 5D CS 375

Geo/Assessors code: 0000007051

*Approved Design Criteria:*

# Bedrooms: 3      Septic Tank Size: 1500 gallons      Drainfield Size: 128 Lineal Feet

**SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!**

***Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.***

Issued By: Kathi Hooper, R.S.


Closure Statement:

I, Andy Mefford, have inspected the system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: [Signature]

Date: 6/15/22

Title: Owner - Installer



**NOTICE:** The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-283-2442

**DISCLAIMER**

This permit is not a guarantee by the Department that the system will function properly  
for a prescribed period of time.

