LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT

Issue Date: 12/12/2021 Expiration Date: 12/12/2022

Property Owner: LBO Properties c/o:

Address: [redacted]

Telephone: [redacted] [redacted]

Installer: Robert Smith (406.261.0258) License No. Obtain license prior to installation (see details below)

XX New Installation ____ Existing System

____ Repair ____ Replacement ____ Extension ____ Other

Describe: Single system serving 2 separate cabins (2 bedrooms each). Systems will be pressure dosed, with 5 laterals @ 75-feet each in length. Absorption trenches to be 3-feet wide with a minimum spacing of 4-feet between trenches (wall-to-wall).

Parcel Description: Rainbow Acres Subdivision Lot 6

Legal: RAINBOW ACRES, S30, T27 N, R27 W, Lot 006

Address or Location: N/A

Geo/Assessors code: 0000054371

Approved Design Criteria:

Bedrooms 2 cabins, 2 bed each Septic Tank Size: 2,000 gal. primary + 1,000 gal. dose/pump

Drainfield Size: 375 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Conditions: INSTALLER MUST OBTAIN LINCOLN COUNTY SEPTIC INSTALLER LICENSE PRIOR TO SYSTEM INSTALLATION.

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT, DEQ-4 AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: Nicholas Raines

Closure Statement:

I, Robert Smith *, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.*

Signed: Robert Smith *Date:* 6-27-23

Title: Licensed Installer