NFIJ

SEPTIC TANK PERMIT
for
LINCOLN COUNTY

Permit Sent _____

Date 8/24/76

Phone [redacted]

Property Owner Bill Lake Address [redacted]

(Access from S-Corner Grocery)


Lot, Block Number, or legal description of Property Sec 33 T30 R31

To be built by: — Square feet absorption area. 170 sq ft.

Septic Tank Size 750 gal # of ~~bedrooms~~ Shop _____ Water Supply Public Water


Description of Absorption Area: Dig a ditch 85 feet in length x 2½-3 feet deep x 2 feet wide according to lot layout and ditch diagram. Grade of pipe should not exceed 1% drop

Sketch; Must include property lines, buildings, and proposed septic tank-drainfield layout. Sketch must show distance from absorption area to wells, springs, streams, or lakes. Indicate depth of water table. Indicate slope.



Ditch Diagram

LOT LAYOUT



Soil: Sandy Clay w/ mixed gravel

Slope: 2-3%

Issued by Ron Anderson Inspected by _____

Date 8/24/76